

CERTIFICATE OF COMPLIANCE

Certificate Number EX28527
Report Reference EX28527-2021-12-29
Date 2022-January-10

Issued to: YUANDA VALVE GROUP CO LTD
Xiyin Village, Long Yao County,
Xingtai Hebei 055350 CN

This is to certify that representative samples of GATE VALVES
See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 262 and ULC/ORD C262-92- Standard for Gate Valves for Fire-Protection Service
UL 746A- Standard for Safety Polymeric Materials – Short Term Property Evaluation

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number EX28527
Report Reference EX28527-2021-12-29
Date 2022-January-10

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Models

USL

Model	Type	Size, in	Rated Pressure, psig	End Configuration
Z41X	O.S&Y	2	300	F by F (ASME Class 125)

USL, CNL

Model	Type	Size, in	Rated Pressure, psig	End Configuration
Z41X	O.S&Y	2.5,3,4,5,6,8,10,12	300	F by F (ASME Class 125)
Z45X	NRS	2.5,3,4,5,6,8,10,12	300	F by F (ASME Class 125)

Note: F - Flange


O.S&Y, outside-screw-and-yoke type

NRS, non-rising stem type

Flanges comply with ASME/ANSI B16.1 Class 250

Face flanges comply with ASME/ANSI 16.10-1

The valves are intended to be installed at working pressures that do not exceed the flange class pressure rating, unless otherwise approved by the Authority Having Jurisdiction.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

